

November 10, 2006

**THIS LETTER REPLACES LETTER DATED OCTOBER 27, 2006.**

SIM / TECH FILTER  
KOTESKEY BROTHERS EXCAVATING INC.  
GARY KOTESKEY  
06598 HORTON BAY N RD.  
BOYNE CITY MI 49712

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)  
Manufacturer: SIM / TECH FILTER  
Product Name: SEPTIC TANK GRAVITY FILTER  
Model Number(s): STF-110  
Product File No: 20060438

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of **November 2011**.

This approval is contingent upon compliance with the following stipulation(s):

- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product may only be installed in the outlet tee baffle of septic tanks or compartments that have a maximum daily flow rate of no more than 1200 gallons per day.

This approval supersedes the approval issued on JANUARY 22, 2002 under product file number 20010540.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010540.

SIM / TECH FILTER  
Page 2  
20060438  
November 10, 2006

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov